



## Declaration of Performance refer to EU BauPVO 305/2011

<b>1 DoP Reference number</b>	BD/G1/3015		
<b>2 Product description</b>	Pump station Muli Max series (all types)		
<b>3 Product-specification: (Numbers or Specification of product)</b>	Diverse		
<b>4 Intended use</b>	Collecting and automatically lifting of faecal-free and/or faecal wastewater over the level of backed-up water		
<b>5 Manufacturer</b>	ACO Passavant GmbH Ulsterstraße 3 D-36269 Philippsthal		
<b>6 Authorised representative</b>	Irrelevant		
<b>7 Assessment and verification of constancy of performance</b>	System 3		
<b>8 Relevant harmonised standard</b>	EN 12050-1:2001-05 and EN 12050-2:2001-05		
<b>9 First year of CE marking</b>	2020		
<b>10 Notified body</b>	LGA (NB-No. 0197)		
<b>11 Type test report reference number</b>	LGA Test Report 60283380-004 (Sita 200/260/300/400/500 N-ex-G) LGA Test Report 60283380-005 (Sat-V 75/ and 150/2/50D) LGA Test Report 60283380-006 (Sat-(100/150/200)/D)		
<b>12 Essential characteristics</b>	<b>Main feature</b>	<b>EN 12050-1/-2</b>	<b>Performance</b>
	Water tightness	4.2	pass
	Exhalation tightness	4.2	pass
	Lifting effect	Section 5	pass
	Mechanical resistance	4.2, 5.2, 5.9 und section 6	pass
	Noise level	Section A.3	< 70 dB
	Durability	4.2, 5.2, 5.9 und section 6	pass
<b>13 Specific technical documentation (article 37/38)</b>	Installation manual		
<b>14 Other information</b>	—		

The performance of the product according to No. 2 and 3 is conform to the declared performance in No 12.  
The manufacturer only is responsible for the creation of this declaration of performance according to No. 5.  
Signed for and on behalf of the manufacturer.

Stadtlengsfeld, 22.04.2020

Peter Fröhlich  
Managing Director

